





PART NUMBER AND MATERIAL DESIGNATION:

DRAWING NO. MODEL NO. MATERIAL:
 C-15854-CS 15854-CS (CARBON STEEL TANK WITH 316/316L
 STAINLESS STEEL WETTED PARTS ON SIGHT GAUGE)
 C-15854-SS 15854-SS (316/316L STAINLESS STEEL CONSTRUCTION)

ORDERING INFORMATION


MODEL NUMBER	TANK MATERIAL	SEAL MATERIAL	SCALE CALIBRATION
15854	CS OR SS	A, B, E, V OR T	SEE TABLE BELOW

EXAMPLE MODEL NUMBER: 15854-SS-V-GPH

SCALE CALIBRATION OPTIONS / DEFINITIONS	MAXIMUM PUMPING RATE/GAUGE VOLUME	SCALE CALIBRATION INCREMENT VALUE
GPH=GALLONS PER HOUR	80	2
LPH=LITERS PER HOUR	302.83	5
GPD=GALLONS PER DAY	1920	25
LPD=LITERS PER DAY	7267.97	100
GBV=GALLONS BY VOLUME	1.33	0.02
LBV=LITERS BY VOLUME	5.05	0.1

NOTE: GPH/LPH/GPD/LPD SCALES ARE BASED ON A ONE MINUTE TEST.

WETTED PARTS: TANK, SIGHT TUBE AND SIGHT TUBE O-RING SEALS



DIMENSIONAL NOTE:
 DIMENSIONS ARE FOR REFERENCE
 PURPOSES ONLY AND ARE SUBJECT TO
 CHANGE AT ANY TIME WITHOUT NOTICE.

INFORMATION IS PROPRIETARY TO KENCO ENGINEERING CO.

REV.	DATE	BY	CHKD.	ECN	EXPLANATION:	KENCO ENGINEERING COMPANY TULSA, OKLAHOMA		
A	06-03-93	RC	-	-	ITEM 4 P/N WAS B-14109	POT, CALIBRATION (OUTLINE) MODEL NO. 15854		
B	12-14-94	RC	-	-	ITEM 4 P/N WAS A-18954, MAT'L WAS 6061-T6 ALUM.			
C	05-05-10	DS	PAS	000008	REDRAWN; WAS HAND DWG.; ITEM 2 DESCRIPTION WAS PYREX GAUGE GLASS			
					ITEM 6 WAS P-13698; ADDED SHEET 2 OF 2; ADDED 13114-A			
						DATE: 11-21-91	SHEET: 1 OF 2	DRAWING NUMBER
						DRN. BY: RC	CHKD. BY:	C-15854
						SCALE: NONE	REVISION: C	