


RATE / VOLUME

SCALE CALIBRATION (UNITS OF MEASURE)	MAXIMUM RATE / VOLUME	SCALE CALIBRATION (DIVISION INCREMENTS)
* GALLONS PER HOUR	2.50	0.05
* LITERS PER HOUR	9.46	0.20
* GALLONS PER DAY	60.00	1.00
* LITERS PER DAY	227.12	5.00
GALLONS BY VOLUME	0.04	0.001
LITERS BY VOLUME	0.16	0.005

* RATE SCALE CALIBRATIONS ARE BASED ON A 1 MINUTE TEST



MODEL 30060-P-GG

DIMENSION ARE FOR REFERENCE PURPOSES ONLY AND ARE
SUBJECT TO CHANGE AT ANY TIME WITHOUT NOTICE.

COPYRIGHT © 2003 KENCO INTERNATIONAL, INC.-ALL RIGHTS RESERVED

REV.	DATE	BY	ECN	EXPLANATION:	KENCO ENGINEERING COMPANY TULSA, OKLAHOMA		
					GAUGE, PUMP SETTING (OUTLINE DRAWING) MODEL 30060-P-GG		
					DATE: 01-31-03	SHEET: 1 OF 1	DRAWING NUMBER
					DRN. BY: DPS	CHKD. BY:	
					SCALE: NONE	REVISION:	C-43607