



RATE / VOLUME

SCALE CALIBRATION (UNITS OF MEASURE)		MAXIMUM RATE/VOLUME	SCALE CALIBRATION (DIVISION INCREMENTS)
* GALLONS	PER HOUR	6.00	0.20
* LITERS	PER HOUR	22.71	0.50
* GALLONS	PER DAY	144.00	5.00
* LITERS	PER DAY	545.10	20.00
GALLONS	BY VOLUME	0.10	0.002
LITERS	BY VOLUME	0.38	0.01

* RATE SCALE CALIBRATIONS ARE BASED ON A 1 MINUTE TEST



MODEL 30144-P

DIMENSIONS ARE FOR REFERENCE PURPOSES ONLY AND ARE
SUBJECT TO CHANGE AT ANY TIME WITHOUT NOTICE.
COPYRIGHT © 2003-KENCO INTERNATIONAL, INC.-ALL RIGHTS RESERVED

REV.	DATE	BY	ECN	EXPLANATION:	KENCO ENGINEERING COMPANY TULSA, OKLAHOMA		
A	04-03-09	EM		0.50 LPH WAS 0.60 LPH	GAUGE, PUMP SETTING (OUTLINE DRAWING) MODEL 30144-P		
					DATE: 01-31-03 SHEET: 1 OF 1 DRAWING NUMBER		
					DRN. BY: DPS CHKD. BY: C-43567		
					SCALE: NONE REVISION: A		